

0035634
Incoming: 9400857

Department of Energy

Richland Operations Office
P.O. Box 550
Richland, Washington 99352

94-RPS-160

MAR 08 1994

Mr. George B. Schlender, Program Manager
Larger On-Site Municipal,
Wastewater Reuse Systems
State of Washington
Department of Health
West 924 Sinto
Spokane, Washington 99201

Dear Mr. Schlender:

INSPECTION RECORD FORM FOR THE HANFORD WASTE VITRIFICATION PLANT RELOCATABLE LATRINE FACILITY

This letter transmits the Inspection Record Form (Form) for the Hanford Waste Vitrification Plant Relocatable Latrine Facility (RLF). This Form is being submitted to fulfill quarterly reporting requirements.

The completed Form is for the operating period of October 1993 through December 1993. The information recorded indicates that the RLF was operating within design limits and that all RLF system components were functioning properly.

Should you have any questions regarding this transmittal, please contact me or Ms. A. L. Rodriguez of my staff on (509) 372-0277.


Sincerely,

James D. Bauer
James D. Bauer, Program Manager
Office of Environmental Assurance,
Permits, and Policy

EAP:ALR

Enclosure:

cc w/o encl:
C. A. Augustine, WHC
J. L. Hensley, Ecology
G. L. Levan, UCAT
J. J. Luke, WHC



Enclosure

943275-0323

UE&C - Catalytic

A Raytheon Company

Organization Engineering Operations

Job Number 9828

File Number

Date January 5, 1994

Memo Number PM-94-0003

To K. A. Giese, WHC AWP (H6-25)

Copies FD Pettit

From G. L. LeVan, UCAT (X2-01)

RG Walker

TM Jennings

NA Mancuso

Subject HWVP Project
HWVP RELOCATABLE LATRINE FACILITY
QUARTERLY INSPECTION RECORD

CA Augustine, WHC (G6-02)


DG Baide, WHC (G6-16)

File

Eng. Ops. File

940325-0324
126152416
The HWVP Relocatable Latrine Facility Operation and Maintenance Manual requires UCAT to submit completed Inspection Record forms on a quarterly basis to the WHC Air and Water Permits (AWP) Function. The WHC AWP is to then provide this information to the Washington State Department of Health.

Attached please find the completed HWVP Relocatable Latrine Facility Inspection Record forms for the period of October 1993 through December 1993. Should you have any questions, please contact Jim Tuel at (509)372-2292.


G. L. LeVan

GLL:st

Attachments

HWVP RELOCATABLE LATRINE FACILITY
INSPECTION RECORD FORM

	ALARM PANEL	HOLDING TANK		
	FLOAT SWITCH/ALARM SIGNAL OPERATION	VOLUME PUMPED (ESTIMATE)	MANHOLE SEAL	INLET AND OUTLET
FREQUENCY	MONTHLY	EVERY PUMP	MONTHLY	ANNUALLY
DATE				
9-17-93		1466		
9-22-93		1749		
9-30-93 [✓]		2236		
10-5-93 [✓]	✓	1536	✓	
10-7-93 [✓]		1676		
10-13-93 [✓]		1468		
10-15-93 [✓]		2097		
10-19-93 [✓]		2000		
10-22-93 [✓]		1816		
10-26-93 [✓]		2100		
10-29-93		1677		
11-2-93	✓	2029	✓	
11-3-93		2099		
11-4-93		2100		
11-5-93		1816		
11-10-93		1676		
11-18-93		1750		
11-18-93		1467		
11-22-93		1258		
11-24-93		1536		
12-1-93	*	1397	✓	

ENG024-07/23/93-RO

* AUDIO ALARM WORKING, BULB DEFECTIVE
ON VISUAL ALARM. POWER CITY TO
REPLACE S

9413275-0325

424

CORRESPONDENCE DISTRIBUTION COVERSHEET

Author

Addressee

Correspondence No.

J. D. Bauer, RL
(K. A. Giese, WHC)

G. B. Schlender, DOH

Incoming:9400857
Xref:9450977D

Subject: INSPECTION RECORD FORM FOR THE HANFORD WASTE VITRIFICATION PLANT
RELOCATABLE LATRINE FACILITY

INTERNAL DISTRIBUTION

Approval	Date	Name	Location	w/att
		Correspondence Control	A3-01	
		C. A. Augustine	G6-16	
		G. D. Carpenter	H6-30	
		D. J. Carrell	H6-22	
		L. P. Diediker	T1-30	
		W. T. Dixon, Assignee	H6-21	
		K. A. Giese	H6-25	
		R. J. Landon	H6-21	
		R. E. Lerch	B3-63	
		P. J. Mackey	B3-15	
		H. E. McGuire, Level 1	B3-63	
		J. J. Luke	H6-25	
		EPIC	H6-08	
		KAG/File/LB	H6-25	

944875 132
128 572646